



**SURREY**  
CITY OF PARKS

CITY OF SURREY  
Planning and Development Department

14245 - 56th Avenue, Surrey  
British Columbia, Canada V3X 3A2

Telephone  
(604) 591-4441

Fax  
(604) 591-2507

November 14, 1997

File: 2151-10400

**Fax: 591-8510**

Mildred Andersen  
Bismart Distributors Inc.,  
8584 - 145A Street  
Surrey, B.C.

Dear Ms. Andersen:

**Re: Envirosink**

With respect to the Envirosink, I have reviewed the literature you have provided and have determined that this product is not regulated by the 1992 B.C. Plumbing Code.

Persons installing this product must be aware of the following regulations regarding the discharge of waste water:

- Surrey Plumbing By-law No. 6569
- The Fisheries Act
- Waste Management Act
- Surrey By-law No. 2240 (regarding sewer discharge)

An air gap must be provided between the top level of this Envirosink and sink faucet.

Provided the installation is installed to manufacturer's recommendations, this would be a good product for recycling water when used for garden irrigation.

This is not an endorsement by the City of Surrey.

If you require further information regarding this product, please contact me at 591-4347.

Yours truly,

Keith Richardson  
Manager  
Plumbing Section

KR/mpr

v:\wp-docs\building\97data\oct-dec\10280921.kr  
MR 11/14/97 11:34 AM